



CASTLE VALVES LTD
C-51 MAYAPURI INDUSTRIAL AREA,
PHASE-2, NEW DELHI 110064
PH: 9582888361,9582888363

DATASHEET FOR HORIZONTAL CHECK VALVES

| | |
|---------------------|-------------------------|
| ITEM | HORIZONTAL CHECK VALVE |
| END CONNECTION | THREADED AS PER BS 21 |
| BODY | FORGED BRASS TO IS 6912 |
| BONNET | FORGED BRASS TO IS 6912 |
| DISC | FORGED BRASS TO IS 6912 |
| O-RING | NITRILE RUBBER |
| SEAT TEST PRESSURE | 13.5 kg/cm ² |
| SHELL TEST PRESSURE | 20 kg/cm ² |